

WEST PIERCE FIRE & RESCUE

Proudly serving the citizens of Lakewood and University Place

3631 Drexler Drive West, University Place, WA 98466 phone 253.564.1623 **I** fax 253.564.1629 **I** www.westpierce.org

Fire Alarm Systems Plan Review Checklist

The following are the minimum requirements needed for submittal of fire alarm systems to be reviewed for approval. Provide 3 sets of all required documentation.

2013 edition of NFPA 72.
Written narrative providing intent and system description to include, but not limited to;
o Describe the project as new, tenant improvement, or remodel.
System drawings shall be provided in $^1/_4$ or $^1/_8$ inch scale. Submitted documents shall include all applicable requirements of NFPA 72. Including, but not limited to the following;
 Documentation should include applicable site drawing, building layout, sectional views and provided point of compass.
 Plans shall show location of all Fire Alarm equipment including but not limited to; initiating devices, notification appliances, candela ratings, control unit, annunciator panel, transponders, power supplies, booster panels, etc.
Provide manufacturer's product information sheets for all devices and appliances integrated with the system.
Battery calculation sheet.
Wire voltage drop calculation sheet.
Riser diagram.
Conductor type, sizes and conduit details.
Operational Matrix.
Elevator recall information, if applicable.

Plans and permits must be submitted to West Pierce Fire & Rescue, Station 20 at 10928 Pacific Hwy SW, Lakewood, WA 98499. For plan submittal or permit questions please contact Administrative Assistant, Loralee Ashley at (253) 983-4583 or Loralee. Ashley@westpierce.org.

For system requirements or plan review questions please contact Michael Dobbs, Battalion Chief/Assistant Fire Marshal at (253) 983-4584 or Michael.Dobbs@westpierce.org.