

Name _____

Address _____

Phone _____

Here

Confidence Test Report

(253) 983-4583 Confidence testing questions

(253) 582-7912 (fax)

<h2>STANDPIPE SYSTEM</h2>		Certification Given	
(One System per Report)		RED <input type="checkbox"/>	YELLOW <input type="checkbox"/>
CONFIDENCE TEST <input type="checkbox"/>	REPAIRS <input type="checkbox"/>	WHITE <input type="checkbox"/>	
Occupancy Address: _____	Occupancy Name: _____		
Building Owner: _____	Phone Number: _____		
Responsible Person: _____	Phone Number: _____		
Building Owner Address: _____			
Date of Inspection: _____	Inspection Frequency/Type: 5 year		
Testers Name (Please Print): _____			
Number of Bldg. Stories: _____	Location of FD Connection: _____		
Primary Component: _____	System Make: _____		
System Model: _____			
System Location: _____	Identification Number: _____		
PROBLEMS FOUND: (If additional room is needed, please add a separate sheet)			
CORRECTIONS MADE:		Date Corrected: _____	Corrected By: _____
(If additional room is needed, please add a separate sheet)			
<p>This certifies that this fire and life safety system has been properly inspected for reliability to cover the items listed in this report and is consistent with National Fire Protection Association standards, and that discrepancies are noted and have been reported to the building Owner/Manager for corrective action.</p>			
Signature of Tester: _____	Phone # _____		
Testing Agency: _____			
Mailing Address: _____			
Building Representative (signature) _____			

The items on the checklists below shall be inspected and tested. This list does not constitute all of the required inspecting and testing of the fire and life safety system. Refer to the NFPA for inspecting and testing requirements.

General

Is there 300 GPM flow at roof through each riser?	N/A <input type="checkbox"/>	Yes <input type="checkbox"/>	No <input type="checkbox"/>
All fire department inlets and outlets equipped with approved plugs or caps (1/8 inch pressure relief hole in caps)?		Yes <input type="checkbox"/>	No <input type="checkbox"/>
Piping between fire department connection and check valve is currently hydro-tested?		Yes <input type="checkbox"/>	No <input type="checkbox"/>
All control valves left in open position (except normally closed valves)?		Yes <input type="checkbox"/>	No <input type="checkbox"/>
Pumper connections are not obstructed?		Yes <input type="checkbox"/>	No <input type="checkbox"/>
Water flow switches operate properly?	N/A <input type="checkbox"/>	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Fire pump(s) start from roof flow?	N/A <input type="checkbox"/>	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Was the Fire Department Connection (FDC) back flushed?		Yes <input type="checkbox"/>	No <input type="checkbox"/>
Are there hose cabinets in the building?		Yes <input type="checkbox"/>	No <input type="checkbox"/>
Is the building sprinklered?		Yes <input type="checkbox"/>	No <input type="checkbox"/>
Standpipe Classification			
Class I Standpipe?		Yes <input type="checkbox"/>	No <input type="checkbox"/>
Class II Standpipe?		Yes <input type="checkbox"/>	No <input type="checkbox"/>
Class III Standpipe?		Yes <input type="checkbox"/>	No <input type="checkbox"/>
Hose cabinet and/or sprinkler PRV testing form for each system?	N/A <input type="checkbox"/>	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Was debris found in the Fire Department Connection (FDC)?		Yes <input type="checkbox"/>	No <input type="checkbox"/>
System gauges replaced every 5 years or calibrated?		Yes <input type="checkbox"/>	No <input type="checkbox"/>

Class I

Hydro-tested 150 psi or 50 psi greater than head pressure for 2 hours (Dry Standpipe Only)		Yes <input type="checkbox"/>	No <input type="checkbox"/>
All outlet valves and hose threads checked and have 2 ½" Cap w/1/8" hole?		Yes <input type="checkbox"/>	No <input type="checkbox"/>
Was 25 psi air test conducted?		Yes <input type="checkbox"/>	No <input type="checkbox"/>
Standpipes have 12" wrench clearance?		Yes <input type="checkbox"/>	No <input type="checkbox"/>

Class II

Hydro-tested 150 psi or 50 psi greater than head pressure for 2 hours:		Yes <input type="checkbox"/>	No <input type="checkbox"/>
Are all hoses, valves and controlling nozzles in good condition?		Yes <input type="checkbox"/>	No <input type="checkbox"/>
Have flow tests been conducted at highest level for at least 30 seconds to make sure nozzle will work at pressure available (50 gpm at 35 psi minimum)?		Yes <input type="checkbox"/>	No <input type="checkbox"/>
Standpipe has 12" wrench clearance?		Yes <input type="checkbox"/>	No <input type="checkbox"/>
Have controlling valves been tested to verify that pressure regulating valves operate properly (not to exceed 100 psi Tip pressure)?		Yes <input type="checkbox"/>	No <input type="checkbox"/>

Class III

Hydro-tested at 150 psi or 50 psi greater than highest Operating pressure?		Yes <input type="checkbox"/>	No <input type="checkbox"/>
Was 25 psi air test conducted?		Yes <input type="checkbox"/>	No <input type="checkbox"/>
All outlet valves and hose threads checked and have 2 ½" Cap w/1/8" hole?		Yes <input type="checkbox"/>	No <input type="checkbox"/>
Flow tests conducted to verify operating pressure of press Regulating valves (not to exceed 175-psi flowing)?		Yes <input type="checkbox"/>	No <input type="checkbox"/>

CLASS II STANDPIPE FIRE HOSE TEST

Length –	Record the actual length of each piece of hose. Give the lineal measure to the closest five feet.
Size –	The inside diameter in inches.
Evaluation –	At the time of testing, fire hose will be evaluated by the tester and placed in one of the following three categories according to NFPA 1962:
Good –	The jacket is intact with no signs of wear and no leaks.
Fair –	The outer jacket is beginning to show signs of wear and no leaks
Poor –	The outer jacket is showing advanced signs of wear and small holes appear in the jacket and/or leaks.